

Elements Required for other Manufacturers

The door shall contain the necessary preparations to accept the vertical deadbolts. Vertically-Stiffened hollow metal doors are recommended. The first stiffener shall be a minimum of five inches from the lock edge of the door.

Vertical deadbolts shall be extended and retracted by threaded rods which shall be inserted into the door and connected to activating arms within the lock mechanism. Deadbolt caps shall be hardened steel or stainless steel. Edge plates are to be installed upon or within U-Channels at the door edge. Edge plates are to be fastened by pop rivets, not screws.

ELEMENTS REQUIRED FROM OTHER MANUFACTURERS:

CYLINDERS & KEYS (Required)

A 1-1/8" long mortise cylinder shall be provided for the MAGLATCH system.

Cylinder manufacturer, keying level and keying information is to be provided separately. Keys per cylinder shall be as specified elsewhere.